

FORM U-1A MANUFACTURERS' DATA REPORT FOR PRESSURE VESSELS
 Alternate Form for Single Chamber Completely Shop-Fabricated Vessels Only
 As Required by the Provisions of the ASME Code Rules, Section VIII, Division I

Manufactured by AMF BEAIRD, INC., SHREVEPORT, LOUISIANA
(Name and address of Manufacturer)

Manufactured for CARDOX CORPORATION, CHICAGO, ILLINOIS
(Name and address of Purchaser)

3. Type Horiz. Vessel No. 176744-06-6 (Mfrs. Serial) (State & State No.) Natl. Bd. No. 99287 Yr. Built 1973
(Horiz. or Vert.)

4. SHELL: Matl. SA-515-70 T.S. 70,000# Nom. 1.082 Corr. 104 6-3/8
(Kind and Spec. No.) (Fig. or F.B. & Spec. Min. T.S.) Thk. In. Allow In. Diam. Ft. In. Length Ft. In.

5. SEAMS: Long Dbl. Butt H.T. Yes R.T. Complete Sectioned No Efficiency 100 %
(Welded, Dbl., Single, Lap, Butt) (Yes or No)¹ (Spot or Complete) (Yes or No)
 Girth Dbl. Butt H.T. Yes R.T. Complete Sectioned No No. of Courses 14

If riveted or brazed describe seams fully under remarks.

6. HEADS: (a) Material SA-515-70 T.S. 70,000# (b) Material See remarks
Location Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Pressure (Convex or Concave)
 (a) Ends .6351" 75.02" Concave
 (b) _____

If removable, bolts used _____ Other fastening _____
(Material, Spec. No., T.S., Size, Number) (Describe or Attach Sketch)

7. Constructed for max. allowable working press.² 250 psi at max. temp. 150 °F. Min. temp. -20 °F. Hydrostatic Test Press 375 psi.

8. SAFETY OR RELIEF VALVE OUTLETS: Number 2 Size 2" Location Top of tank in shell

9. NOZZLES:

Purpose (Inlet, Outlet, Drain)	Number	Diam. or Size	Type	Material	Thickness	Reinforcement Material	How Attached
(3) 3/4" (1) 1"	(1)	6000#	Cplgs.	SA-105-II			Welded
(5) 2"		3000#	Cplgs.	SA-105-II			Welded
(2) 4" (1) 6"		Sch. 80	Seamless Pipe Stubs	SA-106-B			Welded

10. INSPECTION Manholes, No. 1 Size 11" x 15" Location End of tank in head
 OPENINGS: Handholes, No. _____ Size _____ Location _____
 Threaded, No. _____ Size _____ Location _____

11. SUPPORTS: Skirt _____ Lugs _____ Legs _____ Other (2) Saddles Attached shipped loose
(Yes or No) (Number) (Number) (Describe) (Where & How)

12. REMARKS: 150" I.D. x 116' 10" O.A. Length 103,315 W.G. CO2 Storage Tank,
per AMF Beaird Inc. Dwg. Order 176744-06

* Head seams spot X-rayed Joint Eff. 85%
(Brief description of purpose of the vessel as Air Tank, Water Tank, L.P.G., Etc.—State Contents. If postweld heat-treated. List other internal or external pressures with coincident temperature when applicable.)

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division I, 1971 Edition
 Date 3-20 1973 Signed AMF BEAIRD, INC. By R. J. McKinney
(Manufacturer)

Certificate of Authorization No. 804 Expires December 31, 1974

CERTIFICATE OF SHOP INSPECTION

VESSEL MADE BY AMF BEAIRD, INC. at SHREVEPORT, LOUISIANA

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province _____ and employed by EMPLOYERS COMMERCIAL UNION INSURANCE CO. of _____ have inspected the pressure vessel described in this manufacturer's data report on 3-20 1973, and state that to the best of my knowledge and belief, the manufacturer has constructed this pressure vessel in accordance with the applicable sections of the ASME Boiler and Pressure Vessel Code.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this manufacturer's data report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 3-20 1973
 Inspector's Signature [Signature] Commissions N. B. COMM. 2660
Natl Board, State, Province and No.