



DBI, Inc. Quality Inspection and Consulting Services

Reliable...Responsive...Resourceful...Proactive

Williams Field Services

Stewart Dew Point Hickory, PA

7-23-2012

A-Scan Baseline Inspection

Vessel No.: AC- 340

Vessel Name: Propane Condenser

P&ID No: STWT-P01-015



DBI Incorporated

Lincoln Nebraska

4223 Progressive Avenue.Lincoln NE 68504.Telephone: 402-467-1818 Fax: 402-467-1766

Omaha Nebraska

2211 S. 156th Circle.Omaha NE 68130.Telephone:402-330-9612.Fax: 402-330-9640

Overland Park Kansas

11660 West 90th.Overland Park KS 66214.Telephone: 913-888-2321 Fax: 913-888-2351



DBI, Inc. Quality Inspection and Consulting Services

Reliable...Responsive...Resourceful...Proactive

Summary Report

Report Reviewed By:

API 510 #30888

Client: Williams Field Services

Location: Stewart Dew Point Hickory, PA

Vessel No.: AC- 340

Vessel Name: Propane Condenser

Inspection Date: 7-23-2012

Type of Inspection: A-Scan Baseline Inspection

Note: An A-Scan baseline inspection was performed on the AC- 340 Propane Condenser. The AC- 340 Propane Condenser meets MAWP of 300 psi with a remaining service life of 20+ years. The long and short term corrosion rates were determined using the nominal thickness of the vessel.

Next UT Inspection: 7/22/2017

API 510 para. 6.4

Next Visual Inspection: 7/22/2017

								Short Term	Long Term	Remaining
								Corrosion	Corrosion	Life
	TNom	Top	Bottom	North	South	East	West	Rate	Rate	(Years)
TML 1	0.500	0.518	0.495					0.001	0.001	20+
TML 2	0.500	0.502	0.503					<1 mil	<1 mil	20+
TML 3	0.500	0.506	0.503					<1 mil	<1 mil	20+



Client: Williams Field Services
Location: Stewart Dew Point Hickory, PA

Vessel No.: AC- 340
Vessel Name: Propane Condenser

Vessel Parameters

Design Pressure (MAWP):	300 psi	North Head Material:	SA-516-70
Design Temperature:	225 F	North Head Type:	Flat
Operating Pressure:	215 psi	Allowable Stress:	20,000
Operating Temperature:	167 F	Joint Efficiency:	Corner Joint
Diameter: I.D or O.D	Fr 5.8138", Bk 9.875"	South Head Material:	SA-516-70
Length S/S:	12' 11"	South Head Type:	Flat
Shell Material:	None	Allowable Stress:	20,000
Allowable Stress:	None	Joint Efficiency:	Corner Joint
Joint Efficiency:	None	Date Manufactured:	2008
Corrosion Allowance:	.125	In Service Date:	2008

ASME CODE EDITION USED FOR CALCULATIONS ASME Section VIII, Division 1. 2001 Edition

Paint Information

Average paint coating thickness:	N/A	Thickness measured with paint:	N/A
Paint Multiplier:	N/A	Thickness measured without paint:	N/A

Name Plate Information

U1A Available:	Yes	ASME stamp present on vessel:	Yes
Name Plate present:	Yes	Rubbing taken:	Digital Photo



Client: Williams Field Services

Location: Stewart Dew Point Hickory, PA

Vessel No.: AC- 340

Vessel Name: Propane Condenser

Vessel Data

Vessel Class:	2	Date Manufactured:	2008
Manufactures Serial #:	2008B5331-A	In Service Date:	2008
Product in Vessel:	Propane	Date of ASME VIII Vessel	2004
		Mfg. under:	
P&ID Drawing #:	015	Code Cases:	N/A
P&ID Prepared By:	Laurel Mountain Midstream, LLC	Addenda:	2006 ADD
Manufacturer:	SmithCo	National Board Number:	11573
Vessel Length S/S:	12' 11"	Vessel Insulated:	No
Diameter I.D or O.D:	Fr 5.8138", Bk 9.875"	Describe openings (if any):	N/A
No. of Shell Sections:	N/A	ANSI Flange Rating:	300 #
No. of Nozzles:	4	Vessel Orientation:	Horizontal
Design Pressure (MAWP):	300 psi	Operating Pressure:	215 psi
Design Temperature:	225 F	Operating Temperature:	167 F
North Head Type:	Flat	South Head Type:	Flat
North Head Material:	SA-516-70	South Head Material:	SA-516-70
North Head Weld Type:	Corner Joint	South Head Weld Type:	Corner Joint
Shell Material:	None	Shell Weld Type:	N/A
Radiography:	N/A	Hydrostatic:	390 psi

Relief Valve Information


Relief Valve Tag Number:	330	Relief Valve Pressure Setting:	300 psi
Relief Valve Test Date:	9/10	Relief Valve Size:	1" x 1"



DBI, Inc. Quality Inspection and Consulting Services

Reliable...Responsive...Resourceful...Proactive

PRESSURE VESSEL EXTERNAL INSPECTION

Client: Williams Field Services Date Inspected: 7-23-2012
Location: Stewart Dew Point Hickory, PA Inspector(s): Mike Troyer
Vessel No.: AC- 340
Vessel Name: Propane Condenser Signature: 

NAME PLATE

Item Inspected	Yes	No	NA = Not Applicable	Comments:
Name Plate present & legible	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Good condition
National Board #	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	11573
Manufacturer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	SmithCo
Serial #/ Year Built	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2008B5331-A/ 2008
Repair or Rerate Name Plate	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A

FOUNDATION

Concrete condition (spalling, cracks)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	None noted
Foundation settling	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Appears level
Coating condition	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
Cradle supports (moisture, cracks)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	None noted

SUPPORTS

Describe type (legs, saddle, etc.)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Legs
Corrosion, pitting (describe)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	None noted
Weld condition	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Good condition
Paint condition	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	No paint failure noted
Anchor bolts (tightness & corrosion)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Appears tight
Insulation deterioration	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A

SHELL

Corrosion, pitting (describe)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
Bulges/ Blisters/ Deformations	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
Weld condition	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
Paint condition	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
Insulation deterioration	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
Biological growth	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
UT Measurements	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A



HEADS

Item Inspected	Yes	No	NA = Not Applicable	Yes	No	N/A	Comments:
Corrosion, pitting (describe)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	None noted
Bulges/ Blisters/ Deformations	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	None noted
Weld condition	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Good condition
Paint condition	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	No paint failure noted
Insulation deterioration	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
UT Measurements	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	See autocad drawing

MANWAYS & NOZZLES

Corrosion, pitting (describe)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	None noted
Weld condition	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Good condition
Flange condition	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Good condition
Bolting condition	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Good condition
Repad condition	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
Insulation deterioration	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
UT Measurements	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	See autocad drawing

APPURTENANCES

Grounding (tightness & corrosion)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Ground connection is tight
Gauges, Sight glass (damage)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	No damage noted
Relief Valve #/ Size/ Set Pressure	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	330/ 1" x 1"/ 300 psi

LADDERS, STAIRS, PLATFORMS

Corroded, Broken Parts	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	None noted
Paint condition	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	No paint failure noted
Wear (ladder rungs, stair treads)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	None noted
Handrails secure	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Handrails are secure
Flooring condition	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Good condition
Tightness (bolts, tie down clips)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Appear tight
Attachment welds	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Good condition
Corrosion, pitting (describe)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	None noted

ADDITIONAL COMMENTS:

TP 11573

CERTIFIED BY SMITHCO ENGINEERING, INC.
TULSA, OKLAHOMA



MAWP 300 PSIG AT 225
INTERNAL INTERNAL

MAWP PSIG AT
EXTERNAL EXTERNAL

MDMT 0 °F AT 300 PSIG

S/N 2008B5331 A YB 2008

TEST PRESS. 300 PSIG ITEM AC-300-1

SERVICE: PROPANE

P215

FORM U-1A MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
(Alternative Form for Single Chamber, Completely Shop or Field Fabricated Vessels Only)
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

1. Manufactured and certified by SMITHCO Engineering, Inc., 6211 S. 39th W. Avenue, Tulsa, Oklahoma 74132
(Name and address of manufacturer)
2. Manufactured for PREMIER INDUSTRIES, INC Harvey, LA
(Name and address of purchaser)
3. Location of installation Premier Industries, Inc. unknown
(Name and address)

4. Type Horiz(Non-Cir) 2008B-5331-A 2008B-5331 11573 2008
(Horiz. or vert. tank) (Mfg's serial No.) (CRN) (Drawing No.) (Nat'l Bd. No.) (Year built)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE.

The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 2007
Year

6. Shell/Tube & Plug Sheets: SA-516 GR-70 N Fr 1.000/ Bk 1.250 .1250 Fr 0' 5.8138"/Bk 0' 9.8750" 12' 11.0000"
Mat'l. (Spec. No., Grade) (Nom. Thk. (in.)) (Corr. Allow. (in.)) (Diam. I.D. (ft. & in.)) (Length (overall) (ft. & in.))

7. Seams: Corner Joint 100 1150 60min. 1
Long (Welded, Dbl., Spot, Lap, Butt) R.T. (Spot or Full) Ell(%). H.T. Temp. (°F) Time (hr) Girth (Welded, Dbl., Spot, Lap, Butt) R.T. (Spot, Partial or Full) No. of Courses

8. Heads: (a) Mat'l. (a) Covers: SA-516 GR-70 N (b) Mat'l. (b) Ends: SA-516 GR-70 N
(Spec. No., Grade) (Spec. No., Grade)

	Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	Fr/Bk	0.500/0.500	0.1250	--	--	--	--	--	2.8125/1.8750 x 155.0000	Flat
(b)	Fr/Bk	0.500/0.500	0.1250	--	--	--	--	--	2.8125/1.8750 x 9.3125/9.3125	Flat

If removable, bolts used (describe other fastenings) N/A
(Mat'l., Spec. No., Gr., Size, No.)

9. MAWP 300 psi at max. temp 225 °F
(internal) (external) (internal) (external)

Min. design metal temp. 0 °F at 300 psi. Hydro., pneu., or comb. test pressure 390 psi

10. Nozzles, inspection and safety valve openings:

Purpose (Inlet, Outlet, Drain)	No.	Diameter or Size	Type	Material	Nominal Thickness	Reinforcement Material	How Attached	Location
Inlet	2	4"300/160	RFWN	SA-105/SA-106B	0.531	Integral	UW-16.1(a)	Front Head
Outlet	2	2"300/160	RFWN	SA-105/	0.344	Integral	UW-16.1(a)	Front Head
Vent/Drain	2	1.0	6000CPLG	SA-105		Integral	UW-16.1(a)	Back Head

11. Supports: Skirts No Lugs 4 Legs 4 Other Attached Welded to covers
(Yes or No) (No.) (No.) (Describe) (Where and how)

12. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report:

(Name of part, item number, Mfg's name and identifying stamp)

Impact testing exempt per: UG-20(f) Item: AC-360 STEW Service: PROPANE

Stay Plate: Front(1)SA-516 GR-70 0.5000 x 0.1250 x 153.6875 x 2.8125

Tubes: SA-214 WLD- 333 x 1.00" x .083" x 42.0000'-Straight


Constructed in conformance with appendix 28

CERTIFICATE OF SHOP/FIELD COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1. "U" Certificate of Authorization No. 4175 expires February 28th, 2009.
Date 09-18-2008 Co. name SMITHCO Engineering, Inc. Signed [Signature]
(Manufacturer) (Representative)

CERTIFICATE OF SHOP/FIELD INSPECTION

Vessel constructed by SMITHCO Engineering, Inc. at Tulsa, Oklahoma
I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of Province of Oklahoma and employed by Seneca Insurance Company of Texas
have inspected the component described in this Manufacturer's Data Report on 9/18 2008, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.
Date 10/22/08 Signed [Signature] Commissions NB12736 A OK914
(Authorized Inspector) (Nat'l Board (incl. endorsements), State, Prov. and No.)



NOTES

1. P&ID NO: STWT-P01-015
- 2.
- 3.
- 4.
- 5.
- 6.

CLIENT: Williams Field Services	DBI, Incorporated 5330 N. 57th Street Lincoln, Nebraska 68507	
LOCATION: Stewart Dew Point Hickory. PA		
INSPECTION DATE: 7-23-2012	ACAD DWG. FILE: AC-340	
VESSEL No: AC-340	DWN BY: MCS	CKD BY:
VESSEL ID: Propane Condenser	MECHANICAL INTEGRITY INSPECTION	