



DBI, Inc. Quality Inspection and Consulting Services

*Reliable...Responsive...Resourceful...Proactive*

Williams Field Services

Stewart Dew Point Hickory, PA

7-18-2012

A-Scan Baseline Inspection

Vessel No.: E-130

Vessel Name: Chiller

P&ID No: STWT-P01-006



**DBI Incorporated**

**Lincoln Nebraska**

4223 Progressive Avenue.Lincoln NE 68504.Telephone: 402-467-1818 Fax: 402-467-1766

**Omaha Nebraska**

2211 S. 156<sup>th</sup> Circle.Omaha NE 68130.Telephone:402-330-9612.Fax: 402-330-9640

**Overland Park Kansas**

11660 West 90th.Overland Park KS 66214.Telephone: 913-888-2321 Fax: 913-888-2351



DBI, Inc. Quality Inspection and Consulting Services

*Reliable...Responsive...Resourceful...Proactive*

## Summary Report

Report Reviewed By:

API 510 #30888

Client: Williams Field Services

Location: Stewart Dew Point Hickory, PA

Vessel No.: E-130

Vessel Name: Chiller

Inspection Date: 7-18-2012

Type of Inspection: A-Scan Baseline Inspection

Note: An A-Scan baseline inspection was performed on the E-130 Chiller. The E-130 Chiller meets MAWP of 210 psi with a remaining service life of 20+ years. The long and short term corrosion rates were determined using the nominal thickness of the vessel. The insulation is saturated throughout the entire vessel.

Next UT Inspection: 7/17/2017

API 510 para. 6.4

Next Visual Inspection: 7/17/2017

								Short Term	Long Term	Remaining
								Corrosion	Corrosion	Life
	TNom	Top	Bottom	North	South	East	West	Rate	Rate	(Years)
TML 1	0.375	0.376	0.378			0.377	0.377	<1 mil	<1 mil	20+
TML 2	0.375	0.375	0.378			0.380	0.379	<1 mil	<1 mil	20+



Client: Williams Field Services

Location: Stewart Dew Point Hickory, PA

Vessel No.: E-130

Vessel Name: Chiller

### Vessel Parameters

Design Pressure (MAWP):	210 psi	North Head Material:	SA-516-70
Design Temperature:	150 F	North Head Type:	2:1 Ellipsoidal
Operating Pressure:	.5 psi	Allowable Stress:	20,000
Operating Temperature:	-41 F	Joint Efficiency:	.85
Diameter: I.D or O.D	40" OD	South Head Material:	SA-516-70N
Length S/S:	22'-6"	South Head Type:	2:1 Ellipsoidal
Shell Material:	SA-516-70	Allowable Stress:	20,000
Allowable Stress:	20,000	Joint Efficiency:	1.0
Joint Efficiency:	.70	Date Manufactured:	2008
Corrosion Allowance:	.125	In Service Date:	2008

### ASME CODE EDITION USED FOR CALCULATIONS

ASME Section VIII, Division 1. 2007 Edition

### Paint Information

Average paint coating thickness:	N/A	Thickness measured with paint:	N/A
Paint Multiplier:	N/A	Thickness measured without paint:	N/A

### Name Plate Information

U1A Available:	Yes	ASME stamp present on vessel:	Yes
Name Plate present:	Yes	Rubbing taken:	Digital Photo



Client: Williams Field Services

Location: Stewart Dew Point Hickory, PA

Vessel No.: E-130

Vessel Name: Chiller

### Vessel Data

Vessel Class:	2	Date Manufactured:	2008
Manufactures Serial #:	13007-6	In Service Date:	2008
Product in Vessel:	Process Gas	Date of ASME VIII Vessel	2007
		Mfg. under:	
P&ID Drawing #:	006	Code Cases:	N/A
P&ID Prepared By:	Laurel Mountain Midstream, LLC	Addenda:	2007
Manufacturer:	Heat Transfer Systems, Inc.	National Board Number:	1918
Vessel Length S/S:	22'-6"	Vessel Insulated:	Yes
Diameter I.D or O.D:	40" OD	Describe openings (if any):	1 3/4" Ports
No. of Shell Sections:	4	ANSI Flange Rating:	N/A
No. of Nozzles:	16	Vessel Orientation:	Horizontal
Design Pressure (MAWP):	210 psi	Operating Pressure:	.5 psi
Design Temperature:	150 F	Operating Temperature:	-41 F
North Head Type:	2:1 Ellipsoidal	South Head Type:	2:1 Ellipsoidal
North Head Material:	SA-516-70	South Head Material:	SA-516-70N
North Head Weld Type:	Single Butt	South Head Weld Type:	Single Butt
Shell Material:	SA-516-70	Shell Weld Type:	Type 1
Radiography:	None	Hydrostatic:	65 psi

### Relief Valve Information

Relief Valve Tag Number:	130A/B	Relief Valve Pressure Setting:	210 psi
Relief Valve Test Date:	9/10	Relief Valve Size:	3" x 4"



DBI, Inc. Quality Inspection and Consulting Services

*Reliable...Responsive...Resourceful...Proactive*

## PRESSURE VESSEL EXTERNAL INSPECTION

Client: Williams Field Services Date Inspected: 7-18-2012  
Location: Stewart Dew Point Hickory, PA Inspector(s): Mike Troyer  
Vessel No.: E-130  
Vessel Name: Chiller Signature:

### NAME PLATE

Item Inspected	Yes	No	NA = Not Applicable	Comments:
Name Plate present & legible	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Good condition
National Board #	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1918
Manufacturer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Heat Transfer Systems, Inc.
Serial #/ Year Built	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	13007-6/ 2008
Repair or Rerate Name Plate	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Vessel has been re-rated

### FOUNDATION

Concrete condition (spalling, cracks)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	None noted
Foundation settling	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Appears level
Coating condition	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
Cradle supports (moisture, cracks)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	None noted

### SUPPORTS

Describe type (legs, saddle, etc.)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Legs
Corrosion, pitting (describe)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	None noted
Weld condition	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Good condition
Paint condition	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	No paint failure noted
Anchor bolts (tightness & corrosion)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Appears tight
Insulation deterioration	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A

### SHELL

Corrosion, pitting (describe)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
Bulges/ Blisters/ Deformations	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
Weld condition	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
Paint condition	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
Insulation deterioration	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Insulation saturated
Biological growth	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Light biological growth
UT Measurements	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	See autocad drawing



## HEADS

Item Inspected	Yes	No	NA = Not Applicable	Yes	No	N/A	Comments:
Corrosion, pitting (describe)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				N/A
Bulges/ Blisters/ Deformations	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				N/A
Weld condition	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				N/A
Paint condition	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				N/A
Insulation deterioration	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				Insulation saturated
UT Measurements	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				See autocad drawing

## MANWAYS & NOZZLES

Corrosion, pitting (describe)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				N/A
Weld condition	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				N/A
Flange condition	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				N/A
Bolting condition	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				N/A
Repad condition	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				N/A
Insulation deterioration	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				Insulation saturated
UT Measurements	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				See autocad drawing

## APPURTENANCES

Grounding (tightness & corrosion)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				Ground connection is tight
Gauges, Sight glass (damage)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				No damage noted
Relief Valve #/ Size/ Set Pressure	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				130A/B/ 3" x 4"/ 210 psi

## LADDERS, STAIRS, PLATFORMS

Corroded, Broken Parts	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				N/A
Paint condition	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				N/A
Wear (ladder rungs, stair treads)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				N/A
Handrails secure	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				N/A
Flooring condition	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				N/A
Tightness (bolts, tie down clips)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				N/A
Attachment welds	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				N/A
Corrosion, pitting (describe)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				N/A

## ADDITIONAL COMMENTS:





DBI, Inc. Quality Inspection and Consulting Services

*Reliable...Responsive...Resourceful...Proactive*

<b>Code Symbol</b>		1918	
		CERTIFIED BY HEAT TRANSFER SYSTEMS, INC. ST. LOUIS MO.	
<b>Code Marks</b>		<b>Max. Allowable Working Pressure</b>	
		Shell-side	PSIG @ °F
		150	150
RTL PHT		Tube-side	1000 150
<b>User Order No.</b>		<b>Min. Design /Metal Temp.</b>	
08-1206		Shell-side	°F @ PSIG
<b>User Equip No.</b>		Tube-side	-50 / 50
E-130		Shell-side	-50 1000
<b>Mfg. Serial No. Year Built</b>		<b>Max. Allowable Ext. Working Pressure</b>	
13007-6 2008		PSIG @ °F	
		Shell-side	
		Tube-side	

RE-RATED BY :	
PREMIER IND. INC.	
	MAY/P 210 PSI
	AT 150 °F
FILE NO. 22	
R-6007	06-2009

**DBI, Inc. Quality Inspection and Consulting Services***Reliable...Responsive...Resourceful...Proactive*

C-130

**FORM U-1 MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS**  
As Required by the Provisions of the ASME Boiler and Pressure Vessel Code Rules, Section VIII, Division I

1. Manufactured and certified by HEAT TRANSFER SYSTEMS, INC., 8100 POLK, ST. LOUIS, MO. 63111  
(Name and address of Manufacturer)  
2. Manufactured for PREMIER INDUSTRIES, 3450 PETERS ROAD, HARVEY, LA. 70059  
(Name and address of Purchaser)  
3. Location of installation UNKNOWN  
(Name and address)  
4. Type: HORIZONTAL HEAT EXCHANGER 13007-6  
(Horizontal, vertical, or sphere) (Tank, separator, jkt., vessel, heat exch., etc.) (Manufacturer's serial number)  
N/A B-3007-6-01 1918  
(CRN) (Drawing number) (National Board number) (Year built)  
5. ASME Code Section VIII Div 1 2007 Ed / A 2007 N/A N/A  
(Edition and Addenda (date)) (Code Case number) (Special Service per UG-120(d))

*Items 6-11 incl. to be completed single wall vessels, jackets of jacketed vessels, shell of heat exchangers, or chamber of multi-chamber vessels.*

6. Shell: (a) Number of course (s)			4		(b) Overall Length			22' - 6"									
No.	Course(s)		Material Spec./Grade or Type	Thickness		Long. Joint (Cat. A)				Circum. Joint (Cat. A B & C)				Heat Treatment			
	Diameter	Length		Nom.	Corr.	Type	Full	Spot	None	Eff.	Type	Full	Spot	None	Eff.	Temp.	Time
2	40"	8' - 0"	SA-516, Gr. 70	0.3750"	0.1250"	1	NONE		70%	1	NONE			70%			
1	40"	4' - 0 1/2"	SA-516, Gr. 70	0.3750"	0.1250"	1	NONE		70%	1	NONE			70%			
1	40" X 23"	2' - 5 1/2"	SA-516, Gr. 70	0.3750"	0.1250"	1	NONE		70%	1	NONE			70%			

7. Heads: (a) SA-516, Gr. 70														(b)																	
(Material spec. number, grade or type)														(H. T. - time & temp)		(Material spec. number, grade or type)														(H. T. - time & temp)	
	Location (Top, Bottom, Ends)	Thickness		Radius		Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure		Category A																			
		Min.	Corr.	Crown	Knuckle					Convex	Concave	Type	Full	Spot	None	Eff.															
(a)	R - END	0.312"	0.125"			2:1					X	S			NONE	85%															
(b)																															

If removable, bolts used (describe other fastenings)

8. Type of jacket \_\_\_\_\_ (Material spec. number, grade, size, number)  
jacket closure \_\_\_\_\_  
If bar, give dimensions \_\_\_\_\_ (Describe as ogee & weld, bar, etc.)  
If bolted, describe or sketch \_\_\_\_\_

9. MAWP 50 at max temp. 150 Min. design metal temp. -50 at 50  
(Internal) (External) (Internal) (External)

10. Impact Test NONE PER UG-20 (f), UCS-66, AND UHA-51 at test temperature of \_\_\_\_\_  
(Indicate yes or no and the component(s) impact tested)

11. Hydro., Pneu., or comb. test press. HYDRO - 65 PSI Proof Test \_\_\_\_\_

*Items 12 and 13 to be completed tube sections.*

12. Tubesheet SA-240, TP304 30 3/4" 3 1/4" 0" BOLTED  
(Stationary (Material spec. number)) (Diameter (subject to press.)) (Nominal thickness) (Corr. Allow.) (Attachment (welded or bolted))  
13. Tubes SA-249, TP304 WLD 3/4" 0.065" Avg. 174 U - TUBES  
(Floating (Material spec. number)) (Diameter) (Nominal thickness) (Corr. Allow.) (Type (Straight or U))  
(Material spec. number, grade or type) (O. D.) (Nominal thickness) (Number)

*Items 14-18 incl. To be completed for inner chambers of jacketed vessels or channels of heat exchangers.*

14. Shell:			(a) Number of course (s):			1			(b) Overall Length			10"		
Courses			Material		Thickness		Long. Joint (Cat A)			Circum. Joint (Cat. A B & C)		Heat Treatment		
No.	Diameter	Length	Spec./Grade or Type		Nom.	Corr.	Type	Full, Spot, None	Eff.	Type	Full, Spot, None	Eff.	Temp.	Time
1	24"	10"	SA-516, Gr. 70N		0.8750"	0.1250"	1	FULL	100%	1	FULL	100%	1150 F.	0.92 Hr.

15. Heads: (a) SA-516, Gr. 70N 1150 F. 0.92 Hr. (b)														
(Material spec. number, grade or type) (H. T. - time & temp) (Material spec. number, grade or type) (H. T. - time & temp)														
	Location (Top, Bottom, Ends)	Thickness		Radius		Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure		Category A		
		Min.	Corr.	Crown	Knuckle					Convex	Concave	Type	Full, Spot, None	Eff.
(a)	L - END	0.812"	0.125"			2:1					X	S	NONE	100%
(b)														

If removable, bolts used (describe other fastenings)

1 3/8"- 24 PCS OF SA-193-B7 STUDS AND 1 3/8"- 48 PCS OF SA-194-2H NUTS  
(Material spec. number, grade, size, number)





## DBI, Inc. Quality Inspection and Consulting Services

Reliable...Responsive...Resourceful...Proactive

## Form U-1 (Back)

C-130

1000 at max temp. 150 Min. design metal temp. -50 at 1000  
(Internal) (External) (Internal) (External)  
Impact Test NONE PER UG-20 (f), UCS-66, AND UHA-51 at test temperature of \_\_\_\_\_  
Indicate yes or no and the component(s) impact tested  
6. Hydro., pneu., or comb. test press. HYDRO - 1300 PSI Proof Test \_\_\_\_\_

19. Nozzles, inspection, and safety valve openings:

Purpose Inlet, Outlet, Drain, etc.	No.	Diameter or Size	Flange Type	Material		Nozzle Thickness		Reinforcement Material	How Attached		Location (Insp. Open.)
				Nozzle	Flange	Nom.	Corr.		Nozzle	Flange	
S-LIQUID INLET	1	6"	RFWN	SA-106-B SML	SA-105	0.2800"	0.1250"		c	b	
S-VAPOR OUTLET	1	12"	RFWN	SA-106-B SML	SA-105	0.3750"	0.1250"		c	b	
S-LO / TI / PI / RVR	4	1/2" - 1 1/2"	CPLG	--	SA-105	3000#	0.1250"		c	--	
S-PSV	1	4"	RFWN	SA-106-B SML	SA-105	0.2370"	0.1250"		c	b	
S-LB / DRAIN NOZZLE	3	2"	RFWN	SA-106-B SML	SA-105	0.2180"	0.1250"		c	b	
T-INLET / OUTLET	2	4"	RFWN	SA-106-C SML	SA-105	0.6740"	0.1250"		c	b	
T-HIS	4	1"	CPLG	--	SA-105	3000#	0.1250"		c	--	

20. Supports: Skirt NO Lugs N/A Legs N/A Others SADDLE SUPPORTS Attached WELDED TO SHELL  
(Yes or No) (Number) (Number) (Describe) (Where and how)

21. Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: (List the name of part, item number, Manufacturer's name and identifying number)

22. Remarks

## CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements in this report are correct and that all details of design, material, construction and workmanship of this vessel conform to the ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1.

U Certificate of Authorization 20649 Expires 11/04/2009

Date 10/15/08 Name HEAT TRANSFER SYSTEMS, INC. Signed [Signature] (Representative)

## CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of MO and employed by OneBeacon America Insurance Co. of BOSTON MASS., and have inspected the pressure vessel described in this Manufacturer's Data Report on 11-4-08, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. By signing this certificate neither the Inspector nor his/her employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his/her employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 11-4-08 Signed [Signature] Commissions A/B9098(A)/MO-0213 (Authorized Inspector) (National Board (incl endorsements) State, Province and number)

## CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the statements on this report are correct and that the field assembly construction of all parts of this vessel conforms with the requirements of ASME BOILER AND PRESSURE VESSEL CODE Section VIII, Division 1. U Certificate of Authorization No. \_\_\_\_\_ Expires \_\_\_\_\_

Date \_\_\_\_\_ Name \_\_\_\_\_ Signed \_\_\_\_\_ (Assembler) (Representative)

## CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of \_\_\_\_\_ and employed by \_\_\_\_\_ have compared the statements in this Manufacturer's Data Report with the described pressure vessel of \_\_\_\_\_ and state that parts referred to as data items \_\_\_\_\_ not included in the certificate of shop inspection, have been inspected by me and to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with the ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. The described vessel was inspected and subjected to a hydrostatic test of \_\_\_\_\_. By signing this certificate neither the Inspector nor his/her employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his/her employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date \_\_\_\_\_ Signed \_\_\_\_\_ Commissions \_\_\_\_\_ (Authorized Inspector) (National Board (incl endorsements) State, Province and number)



DBI, Inc. Quality Inspection and Consulting Services

Reliable...Responsive...Resourceful...Proactive

E730  
GAS CHILLER

**FORM U-1 MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS**  
Required by the Provisions of the ASME Boiler and Pressure Vessel Code Rules, Section VIII, Division I

Manufactured and certified by HEAT TRANSFER SYSTEMS, INC., 8100 POLK, ST. LOUIS, MO. 63111  
Manufactured for PREMIER INDUSTRIES., 3450 PETERS ROAD, HARVEY, LA. 70059  
Location of installation UNKNOWN  
4. Type: HORIZONTAL (Name and address) HEAT EXCHANGER (Tank, separator, jkt., vessel, heat exch., etc.) 13007-7  
(CRN) N/A (Drawing number) B-3007-6-01 (National Board number) 1919 (Manufacturer's serial number) 2008  
5. ASME Code Section VIII Div 1 2007 Ed / A 2007 (Code Case number) N/A (Year built) N/A  
[Edition and Addenda (date)] [Special Service per UG-120(d)]

Items 6-11 incl. to be completed single wall vessels, jackets of jacketed vessels, shell of heat exchangers, or chamber of multi-chamber vessels.

6. Shell: (a) Number of course (s) 4 (b) Overall Length 22' - 6"

No.	Diameter	Length	Material Spec./Grade or Type	Thickness		Type	Long. Joint (Cat. A)		Circum. Joint (Cat. A B & C)		Heat Treatment		
				Nom.	Corr.		Full	Spot, None	Eff.	Type	Full, Spot, None	Eff.	Temp.
2	40"	8' - 0"	SA-516, Gr. 70	0.3750"	0.1250"	1	NONE	70%	1	NONE	70%		
1	40"	4' - 0 1/2"	SA-516, Gr. 70	0.3750"	0.1250"	1	NONE	70%	1	NONE	70%		
1	40" X 23"	2' - 5 1/2"	SA-516, Gr. 70	0.3750"	0.1250"	1	NONE	70%	1	NONE	70%		

7. Heads: (a) SA-516, Gr. 70 (b) SA-516, Gr. 70

Location (Top, Bottom, Ends)	Thickness		Radius		Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure		Category A	
	Min.	Corr.	Crown	Knuckle					Convex	Concave	Type	Full, Spot, None
(a) R - END	0.312"	0.125"			2:1				X	S	NONE	85%
(b)												

If removable, bolts used (describe other fastenings)

8. Type of jacket jacket closure (Material spec. number grade, size, number)  
If removable, give dimensions (Describe as ogee & weld, bar, etc.)

9. MAWP 50 (Internal) at max temp. 150 (Internal) Min. design metal temp. -50 at 50 (External)  
10. Impact Test NONE PER UG-20 (f), UCS-66, AND UHA-51 at test temperature of   
[Indicate yes or no and the component(s) impact tested]

11. Hydro., Pneu., or comb. test press. HYDRO ~65 PSI Proof Test

Items 12 and 13 to be completed tube sections.

12. Tubesheet SA-240, TP304 30 3/4" 3 1/4" 0" BOLTED  
[Stationary (Material spec. number)] [Diameter (subject to press.)] [Nominal thickness] [Corr. Allow.] [Attachment (welded or bolted)]

13. Tubes SA-249, TP304 WLD 3/4" 0.065" Avg. 174 U - TUBES  
[Floating (Material spec. number)] [Diameter] [Nominal thickness] [Corr. Allow.] [Attachment]  
(Material spec. number, grade or type) (O. D.) (Nominal thickness) (Number) [Type (Straight or U)]

Items 14-18 incl. To be completed for inner chambers of jacketed vessels or channels of heat exchangers.

14. Shell: (a) Number of course (s) 1 (b) Overall Length 10"

Diameter	Length	Material Spec./Grade or Type	Thickness		Type	Long. Joint (Cat. A)		Circum. Joint (Cat. A B & C)		Heat Treatment	
			Nom.	Corr.		Full	Spot, None	Eff.	Type	Full, Spot, None	Eff.
24"	10"	SA-516, Gr. 70N	0.8750"	0.1250"	1	FULL	100%	1	FULL	100%	1150 F. 0.92 Hr.

15. Heads: (a) SA-516, Gr. 70N 1150 F. 0.92 Hr. (b) SA-516, Gr. 70N

Location (Top, Bottom, Ends)	Thickness		Radius		Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure		Category A	
	Min.	Corr.	Crown	Knuckle					Convex	Concave	Type	Full, Spot, None
(a) L - END	0.812"	0.125"			2:1				X	S	NONE	100%
(b)												

removable, bolts used (describe other fastenings) 1 3/8" - 24 PCS OF SA-193-B7 STUDS AND 1 3/8" - 48 PCS OF SA-194-2H NUTS  
(Material spec. number, grade, size, number)





# DBI, Inc. Quality Inspection and Consulting Services

Reliable...Responsive...Resourceful...Proactive

## Form U-1 (Back)

E-130

1000 (Internal) at max temp. 150 (Internal) (External) Min. design metal temp. -50 at 1000  
Impact Test NONE PER UG-20 (f), UCS-66, AND UHA-51 at test temperature of  
8. Hydro., pneu., or comb. test press. HYDRO - 1300 PSI Proof Test  
9. Nozzles, inspection, and safety valve openings:

Purpose (Inlet, Outlet, Drain, etc.)	No.	Diameter or Size	Flange Type	Material		Nozzle Thickness		Reinforcement Material	How Attached		Location (Insp. Open.)
				Nozzle	Flange	Nom.	Corr.		Nozzle	Flange	
LIQUID INLET	1	6"	RFWN	SA-106-B SML	SA-105	0.2800"	0.1250"				
VAPOR OUTLET	1	12"	RFWN	SA-106-B SML	SA-105	0.3750"	0.1250"		c	b	
LO / TI / PI / RVR	4	1/2" - 1 1/2"	CPLG	--	SA-105	3000#	0.1250"		c	b	
PSV	1	4"	RFWN	SA-106-B SML	SA-105	0.2370"	0.1250"		c	--	
LB / DRAIN NOZZLE	3	2"	RFWN	SA-106-B SML	SA-105	0.2180"	0.1250"		c	b	
INLET / OUTLET	2	4"	RFWN	SA-106-C SML	SA-105	0.6740"	0.1250"		c	b	
HIS	4	1"	CPLG	--	SA-105	3000#	0.1250"		c	--	

0. Supports: Skirt NO (Yes or No) Legs N/A (Number) Others SADDLE SUPPORTS Attached WELDED TO SHELL (Describe)  
1. Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: (List the name of part, item number, Manufacturer's name and identifying number) (Where and how)

2. Remarks

## CERTIFICATE OF SHOP COMPLIANCE

I, the undersigned, certify that the statements in this report are correct and that all details of design, material, construction and workmanship of this vessel conform to the ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1.

U Certificate of Authorization 20649 Expires 11/04/2009

Date 11/3/08 Name HEAT TRANSFER SYSTEMS, INC. Signed (Manufacturer)

## CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of MO and employed by OneBeacon America Insurance Co. of BOSTON MASS. have inspected the pressure vessel described in this Manufacturer's Data Report on 11-4-08, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. By signing this certificate neither the Inspector nor his/her employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his/her employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 11-4-08 Signed (Authorized Inspector) Commissions 009098(A) 70-0213 (National Board (incl endorsements) State, Province and number)

## CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE


We certify that the statements on this report are correct and that the field assembly construction of all parts of this vessel conforms with the requirements of ASME BOILER AND PRESSURE VESSEL CODE Section VIII, Division 1. U Certificate of Authorization No. Expires

Date Name (Assembler) Signed

## CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of MO and employed by have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items not included in the certificate of shop inspection, have been inspected by me and to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with the ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. The described vessel was inspected and subjected to a hydrostatic test of By signing this certificate neither the Inspector nor his/her employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his/her employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date Signed (Authorized Inspector) Commissions (National Board (incl endorsements) State, Province and number)



## NOTES

1. P&ID NO: STWT-P01-006
- 2.
- 3.
- 4.
- 5.
- 6.

CLIENT: Williams Field Services	<b>DBI, Incorporated</b> 5330 N. 57th Street Lincoln, Nebraska 68507		
LOCATION: Stewart Dew Point Hickory. PA			
INSPECTION DATE: 7-18-2012	ACAD DWG. FILE: E-130		
VESSEL No: E-130	DWN BY: MCS	CKD BY:	
VESSEL ID: Chiller	MECHANICAL INTEGRITY INSPECTION		