

#### Williams Field Services

Stewart Dew Point Hickory, PA

7-18-2012

A-Scan Baseline Inspection

Vessel No.: V-140 Vessel Name: Cold Separator

P&ID No: STWT-P01-007



#### **DBI** Incorporated

#### Lincoln Nebraska

 $4223\ Progressive\ Avenue. Lincoln\ NE\ 68504. Telephone:\ 402-467-1818\ Fax:\ 402-467-1766$ 

#### Omaha Nebraska

2211 S. 156<sup>th</sup> Circle.Omaha NE 68130.Telephone:402-330-9612.Fax: 402-330-9640

#### **Overland Park Kansas**

11660 West 90th.Overland Park KS 66214.Telephone: 913-888-2321 Fax: 913-888-2351



# **Summary Report**

Report Reviewed By:

API 510 #30888

Client: Williams Field Services

Location: Stewart Dew Point Hickory, PA

Vessel No.: V-140

Vessel Name: Cold Separator

Inspection Date: 7-18-2012

Type of Inspection: A-Scan Baseline Inspection

Note: An A-Scan baseline inspection was performed on the V-140 Cold Separator. The V-140 Cold Separator meets MAWP of 1000 psi with a remaining service life of 20+ years. The long and short term corrosion rates were determined using the nominal thickness of the vessel.

Next UT Inspection: 7/17/2017 API 510 para. 6.4

Next Visual Inspection: 7/17/2017

TICAL VISUAL II	ispection.		7/17/2017							
								Short Term	Long Term	Remaining
						_		Corrosion	Corrosion	Life
	TNom	Тор	Bottom	North	South	East	West	Rate	Rate	(Years)
North Head						1.755				
South Head						1.769				
TML 1	1.625	1.632	1.637			1.639	1.651	<1 mil	<1 mil	20+
TML 2	1.625	1.638	1.654			1.683		<1 mil	<1 mil	20+

#### DBI, Inc. Quality Inspection and Consulting Services



#### Reliable...Responsive...Resourceful...Proactive

Client: Williams Field Services

Location: Stewart Dew Point Hickory, PA

Vessel No.: V-140

Vessel Name: Cold Separator

### **Vessel Parameters**

Design Pressure (MAWP):	1000 psi	North Head Material:	SA-516-70
Design Temperature:	100 F	North Head Type:	2:1 Ellipsoidal
Operating Pressure:	620 psi	Allowable Stress:	20,000
Operating Temperature:	-35 F	Joint Efficiency:	1.0
Diameter: I.D or O.D	60" OD	South Head Material:	SA-516-70
Length S/S:	25'	South Head Type:	2:1 Ellipsoidal
Shell Material:	SA-516-70	Allowable Stress:	20,000
Allowable Stress:	20,000	Joint Efficiency:	1.0
Joint Efficiency:	1.0	Date Manufactured:	2008
Corrosion Allowance:	.125	In Service Date:	2008

# ASME CODE EDITION USED FOR CALCULATIONS ASME Section VIII, Division 1. 2007 Edition

#### **Paint Information**

Average paint coating thickness: N/A Thickness measured with paint: N/A Paint Multiplier: N/A Thickness measured without paint: N/A

#### Name Plate Information

U1A Available: Yes ASME stamp present on vessel: Yes

Name Plate present: Yes Rubbing taken: Digital Photo



Client: Williams Field Services

Location: Stewart Dew Point Hickory, PA

Vessel No.: V-140

Vessel Name: Cold Separator

## Vessel Data

Vessel Class:	2	Date Manufactured:	2008
Manufactures Serial #:	AL-1058-B-26	In Service Date:	2008
Product in Vessel:	Gas	Date of ASME VIII Vessel	2007
		Mfg. under:	
P&ID Drawing #:	007	Code Cases:	2007
P&ID Prepared By:	Laurel Mountain	Addenda:	None
	Midstream, LLC		
Manufacturer:	Premier Industries,	National Board Number:	19
	Inc.		
Vessel Length S/S:	25'	Vessel Insulated:	Yes
Diameter I.D or O.D:	60" OD	Describe openings (if any):	1 3/4" Ports
No. of Shell Sections:	3	ANSI Flange Rating:	600 #
No. of Nozzles:	21	Vessel Orientation:	Horizontal
Design Pressure (MAWP):	1000 psi	Operating Pressure:	620 psi
Design Temperature:	100 F	Operating Temperature:	-35 F
North Head Type:	2:1 Ellipsoidal	South Head Type:	2:1 Ellipsoidal
North Head Material:	SA-516-70	South Head Material:	SA-516-70
North Head Weld Type:	Single Butt	South Head Weld Type:	Single Butt
Shell Material:	SA-516-70	Shell Weld Type:	Single Butt
Radiography:	Full	Hydrostatic:	1300 psi


# Relief Valve Information

Relief Valve Tag Number:	140	Relief Valve Pressure Setting:	1000 ps1
Relief Valve Test Date:	9/10	Relief Valve Size:	1 1/2" x 3"



# PRESSURE VESSEL EXTERNAL INSPECTION

Client: Location: Vessel No.: Vessel Name:	Williams Field Ser Stewart Dew Point V-140 Cold Separator		y, PA	Ins	te Inspected: spector(s): gnature:	7-18-2012 Mike Troyer
vessei maine.	Colu Separator			Sig		<b>9</b>
NAME PLATE						the Tay
Item Inspected Yes No		Yes	No	N/A	Comments:	
Name Plate pres					Good condition	1
National Board	#				19	
Manufacturer					Premier Industr	,
Serial #/ Year B	uilt				AL-1058-B-26	/ 2008
Repair or Rerate	e Name Plate				N/A	
FOUNDATION Concrete condit					None noted	
cracks)	ion (spannig,				None noteu	
Foundation settl	ling				Appears level	
Coating condition	•				N/A	
	(moisture, cracks)				None noted	
SUPPORTS						
	egs, saddle, etc.)				Saddle	
Corrosion, pittir					N/A	
Weld condition	,				N/A	
Paint condition					N/A	
Anchor bolts (ti	ghtness &				N/A	
corrosion						
Insulation deter	ioration	$\boxtimes$			None noted	
SHELL						
Corrosion, pittin	g (describe)				None noted	
Bulges/ Blisters/					N/A	
Weld condition					N/A	
Paint condition					N/A	
Insulation deteri	oration				N/A	
Biological growt					None noted	
UT Measuremen			Ħ	T	See autocad dr	awing
		_ <del></del>			ſ	





TI		٨	n	C
н	H	А	ı,	D

Item Inspected Yes No NA = Not Applicable	Yes	No	N/A	Comments:
Corrosion, pitting (describe)	$\boxtimes$			None noted
Bulges/ Blisters/ Deformations			$\boxtimes$	N/A
Weld condition			$\boxtimes$	N/A
Paint condition			$\boxtimes$	N/A
Insulation deterioration	$\boxtimes$			None noted
UT Measurements	$\boxtimes$			See autocad drawing
NAANNAANO O NIOZZI EG				
MANWAYS & NOZZLES				None noted
Corrosion, pitting (describe) Weld condition				Good condition
Flange condition			H	Good condition Good condition
Bolting condition		<del>  </del> -		
Repad condition Insulation deterioration		<u> </u>		N/A
		<u> </u>	Н	None noted
UT Measurements			Ш	See autocad drawing
APPURTENANCES				
Grounding (tightness & corrosion)				Ground connection is tight
Gauges, Sight glass (damage)				No damage noted
Relief Valve #/ Size/ Set Pressure	$\boxtimes$			140/ 1 1/2" x 3"/ 1000 psi
LADDERS, STAIRS, PLATFORM	IS			
Corroded, Broken Parts	$\boxtimes$			None noted
Paint condition	$\boxtimes$			No paint failure noted
Wear (ladder rungs, stair treads)	$\boxtimes$			None noted
Handrails secure			$\boxtimes$	N/A
Flooring condition			$\boxtimes$	N/A
Tightness (bolts, tie down clips)			$\boxtimes$	N/A
Attachment welds				Good condition
Corrosion, pitting (describe)				None noted

### **ADDITIONAL COMMENTS:**







#### DBI, Inc. Quality Inspection and Consulting Services



#### Reliable...Responsive...Resourceful...Proactive

V-140 Cold Sepertur

FORM U-1A MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS (Alternative Form for Single Chamber, Completely Shop or Field Fabricated Vessels Only)
As Required by the Provisions of the ASME Boiler and Pressure Vessel Code Rules, Section VIII, Division 1 PREMIER INDUSTRIES, INC. 3450 PETERS ROAD HARVEY LOUISIANA 70058 USA Manufactured for STEWART DPC PLANT (Name and address of Purchaser) 3. Location of installation PENNSYLVANIA (Name and address HORIZONTAL AL-1058-B-26 AL-1058-B-26 Sht 1 - 6 2008 (Horizontal or vertical, tank) 5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 (CRN) 2007 Addenda (Code Case numbers) SA-516 70 NORMALIZED 1.625 .125" 5'-0" OD 25'-0" S/S (Corr. allow.) SINGLE V BUTT Full [Length (overall)] 100 1100 F 1.75 SINGLE V BUTT [Long. (welded, dbl., sngl., lap, butt)] [R. T. (spot or full)] (H. T. temp.) (Time, hr) [R. T. (spot 8. Heads: (a) Material SA-516 70 NORMALIZED (b) Material SA-516 70 NORMALIZED (Spec. no., grade) Location (Top. Minimum Knuckle Elliptical Hemispherical Side To Pressure Bottom, Ends) Allowance Thickness Radius Ratio Apex Angle Radius Diameter TOP 1.6747" .125" 2:1 CONCAVE BOTTOM 1.6747" .125 2:1 CONCAVE If removable, bolts used (describe other fastenings) N.A. (Material spec. number, grade, size, number) 9. MAWP 1000 PSIG at max. temp. 0 Psig 100 F Min. design metal temp -50 F at 1000 PSIG Hydro., priexix, bix equitix test pressure 10. Nozzles, inspection, and safety valve openings Purpose Reinforcement let, Outlet, Drain) Туре Material Material INLET 4" 600# RFLWN SA350 LF2 CI 1 1.00" INTEGRAL UW-16.1(c) SHELL GAS OUTLET SA350 LF2 CI 1 4" 600# RFLWN 1.00" INTEGRAL UW-16.1(c) SHELL EG OUTLET 2" 600# RFHB SA350 LF2 CI 1 1.00" INTEGRAL UW-16.1(c) SHELL DRAINS 2" 600# RFLWN SA350 LF2 CI 1 .66" INTEGRAL UW-16.1(c) SUMP HEAD 11. Supports: Skirt NONE NONE SADDLES WELDED TO SHELL (Yes or no (Number) 12. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: Shell: Part No. TF14414 A Forrm U-2A TEX-FAB INC.. "U" Certificate No. 12.031 (Name of part, Item number, Manufacturer's name and identifying stamp) All material impact tested at -50 F Design loading per UG-22(a)(b)(d)(f). Relief protection per UG-125 provided by others. Vessel hydrostatically tested in horizontal position. CERTIFICATE OF SHOP / FIELD COMPLIANCE We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. "U" Certificate of Authorization Number Date C.G. 22-09Co. name PREMIER INDUSTRIES, INC. (Manufacturer CERTIFICATE OF SHOP / FIELD INSPECTION Vessel constructed by PREMIER INDUSTRIES, INC. at 3450 PETERS ROAD HARVEY, LOUISIANA 70058 USA I, the undersigned, holding a valid commiss on issued by the National Board of Boller and Pressure Vessel Inspectors and/or the State or Province of LOUISIANA and employed by ONE BEACON AMERICA INSURANCE COMPAMY have inspected the component described in this Manufacturer's Data Report on to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. By Signing this certificate neither the Inspector nor his/her employer makes any warranty, expressed or VESSEL CODE, section VIII, Division 1. By Signing this certificate neither the inspector nor his/ner employer makes any warranty, expresses implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his/her employer. rd (incl. endorsements), State, Province, and number]

# $\ensuremath{\mathbf{DBI}}$ , Inc. Quality Inspection and Consulting Services



# Reliable... Responsive... Resource ful... Proactive

Manuel	_	As Re	luired by t	FORM U-4 MAN he Provisions of PREMIER PLANT	UFAC	TURER'S DATE							V-140 Cold Sepan
		and certifie	d by	DR.	the	ASME Boiler a	REPOR	T SUPPLI	EMENTARY SH	IEET			Sepen
lanufactu	red fo	or STEW	ART DPC	PREMIER	IND	USTRIES, IN	C. 34	sure ves	sel Code Rule	s. Sec	tion VIII	D:	
Location of     Type:	f insta	llati-	IKI DPC	PLANT			(Name a	nd adds	RS ROAD HA	RVEY	LOUTON	Division	1
4. Type:	riola	ilation P	ENNSYLVA	NIA			(0.1	address	of Manufacturer)		LOUISI	ANA 7005	8 USA
Type:		HO	2 T 2 O 1 m = -				(Name :	and addres	s of Purchaser)				
_	(	Horizontal,	vertical, or sp	here)	_	COLD SEP	(1	Vame and a					
Nozzles, inspect	ion	(CRI	1)		( A	Tank, separator, h L-1058-B-26							
Nozzles, inspect	t,	Diame	alve opening	5;		L-1058-B-26 (Drawing num	SHT 1	- 6		(M	AL-1	058-B-26 er's serial num	
Outlet, Drain, et	1	Vo. or Siz	Flange		Mate	rial			(National	19		n s serial num	nber)
PSV BRIDLE-CON		1 2"60	# REUD	Nozzle		Flange	Noza	zle Thickne:	ss Reinforce	Board n			2008 (Year built)
BRIDLE-EG	-	2"600	# DEUR	-	1	A350-LF2 C	Non	n. Corr.	Materia	ment al	Hov	v Attached	
PI	2	- 000			\	A350-1.F2		1123	" INTEGR	AL	Nozzle	Flange	Location (Insp. Open.)
PT	2	2"600	REUD	-		A350-LF2 CT	,	1.223	INTEGR	AT.	<u> </u>	UW-16.	1 SHELL
BRDL-EG-10	1 2	2"600	REUD	-	51	A350-LF2 CL		" .125"		AL		UW-16.	1 RT. HEAD
RDL-COND-LC	2	2"600# 2"600#	RFLWN	-	134	1350-LF2 CT		1.123.	INTEGRA	T.		UW-16.1	Guna
MANWAY-BLD	_	18"600#	RFHB						INTEGRA	I.		UW-16.1	CHEST
SUMP DRAINS	1	20"580	RFHB SMLS	-	JOA	350-LF2 CL1 350-LF2 CL1	1.00"	.125"	INTEGRAI			UW-16.1	CHES
-	2	2"600#	RFHB	SA333 GR6		-	-	.125"	INTEGRAL INTEGRAL	-	-	UW-16.1 UW-16.1	TOME
-	-	<del>-</del> -	-		SAS	50-LF2 CL1	1.031	.125"	SA516 GR7			UW-16.1	SHELL
-	-	-	<del>-</del>	_	_			.125"	INTEGRAL	-		UW-16.1	SHELL
Data Re	port			-	_		-	-	-	-	-	JW-16.1	SHELL
Item Nur	nber										-		-
12	_	_	- Production	nas a 1" nominal Charpy Impact T	_		2.7 611	otical hea	ad attached at	botton	n end w	ith a Type	1 h
			-	- Jampact I	est v	veld and LLAZ						- 700	r butt weld.
	_			.,,	est v	veld and HAZ	at -50 F					- 1750	T butt weld.
	_				est v	veld and HAZ	at -50 F						r butt weld.
					est v	veld and HAZ	at -50 F					- 170	Toutt weld.
				, y mpact I	Test v	veld and HAZ	at -50 F					- 146	out weld.
				,, mpd( )	Test v	veld and HAZ	at -50 F						outt weld.
				7	Test v	veld and HAZ	at -50 F					7,70	r butt weld.
				T mpact	Test v	veld and HAZ	at -50 F					7,70	Toutt weld.
				Tympuc (	Test v	veld and HAZ	at -50 F					7,70	Toutt weld.
				) impact	Test v	veld and HAZ	at -50 F					7,7,6	Tourt weld.
				The state of the s	Test v	veld and HAZ	at -50 F					7/60	Tourt weld.
				) mpdc()	est v	veld and HAZ	at -50 F					7,50	Tourt weld.
				The state of the s	est v	veld and HAZ	at -50 F					7,50	Tourt weld.
				The state of the s	est v	veld and HAZ	at -50 F					7,760	Tourt weld.
				The state of the s	est v	veld and HAZ	at -50 F					7,760	Tourt weld.
Ilhoraci				The state of the s	est v	veld and HAZ	at -50 F					7760	Tourt weld.
nthorization: Type					est v	veld and HAZ	at -50 F					7760	Tourt weld.
					est v		at -50 F					7760	Tourt weld.
22-09 Na	ime j						at -50 F					7760	Tourt weld.
uthorization: Type  22-69 Na	ime j			No.		59	Expires		3/	222/20	111		Tourt weld.
22-09 Na	ime j		INDUSTR	No. IES, INC. (Manufacturer)		59	Expires Expires	- Cha	3/	222/20	11		Tourt weld.
22-09 Na	me i		INDUSTR	No.		59	Expires Expired	- Cha	3/	22/20	Botte		

